

On-site Effluent Treatment National Testing Programme (OSET NTP)

PERFORMANCE CERTIFICATE Oasis Clearwater S2000 On-site Domestic Wastewater Treatment System OSET NTP Trial 3, 2007/2008

System Tested

Oasis Clearwater S2000 aerated submerged fixed film media treatment unit. Rated design capacity 2,000 litres/day. Total liquid volume 7,512 litres (primary treatment 3,800 litres; secondary treatment 3,721 litres). Emergency storage 2,000 litres. No tertiary treatment (such as UV disinfection) is incorporated.

Test Flow Rate

The **Oasis Clearwater S2000** was tested at 1,000 litres/day (equivalent to servicing a 3-bedroom 5 person household) over an 8 month (35 week) period November 2007 to July 2008 followed by a 1½ month (6 week) high flow test involving 5 days at 2,000 litres per day followed by 1,000 litres/day over the next 5 weeks.

Testing and Evaluation Procedures

A total of 21 daily treated effluent samples of organic matter (BOD) and suspended solids (TSS) from weeks 9, 17 and 27 were tested and evaluated as to meeting the secondary effluent quality requirements of the joint Australia/NZ standard AS/NZS 1547:2000.

A total of 21 daily treated effluent samples of BOD, TSS and faecal coliforms (FC) (weeks 9, 17 and 27) plus 16 samples at six day intervals of total nitrogen (TN), ammonia nitrogen (NH₄-N) and total phosphorus (TP) during weeks 23 through 35 were benchmarked and rated on their median values. In addition, the energy used by the treatment system was assessed on the average of consumption levels over the 16 sample days, weeks 23 to 35.

Meeting AS/NZS 1547:2000 Secondary Effluent Quality Requirements

These requirements are that 90% of all test samples must achieve a BOD of $\leq 20 \text{ g/m}^3$ and TSS of $\leq 30 \text{ g/m}^3$. The **Oasis Clearwater S2000** system **achieved** a performance level of **100%** for both BOD and TSS.

Benchmark Ratings

The **Oasis Clearwater S2000** system **achieved** the following effluent quality ratings:

Indicator Parameters	Median	Std Dev.	Rating	Rating System				
				A+	A	B	C	D
<i>BOD (g/m³)</i>	3	0.9	A+	<5	<10	<20	<30	≥30
<i>TSS (g/m³)</i>	4.8	2.0	A+	<5	<10	<20	<30	≥30
<i>Total nitrogen TN (g/m³)</i>	13.1	2.9	A	<5	<15	<25	<30	≥30
<i>Ammonia Nitrogen NH₄-N (g/m³)</i>	0.2	0.1	A+	<1	<5	<10	<20	≥20
<i>Total phosphorus TP (g/m³)</i>	4.7	0.7	B	<1	<2	<5	<7	≥7
<i>Faecal Coliforms FC (cfu/100mL)</i>	31,000	33,000	C	<10	<200	<10,000	<100,000	≥100,000
<i>Energy consumption (kWh/d)</i>	2.0 (ave)		B-	0	<1	<2	<5	≥5

This Performance Certificate is specific to the **Oasis Clearwater S2000** model as specified above when operated at a flow rate of 1,000 litres/day, and is valid for 5 years from the date below.

For the full OSET NTP report on the performance of the **Oasis Clearwater S2000** system contact Oasis Clearwater Environmental Systems Ltd of Christchurch.

Authorised By:

Ian Gunn, Acting Technical Manager, OSET NTP
9 April 2010