

ENGINEERING  
TOMORROW



# Turning the Water Industry into Energy Neutrality + low water leakage

Water New Zealand Conference & Expo, 21 of Sept. 2017

Global Director & GKAM, Mads Warming, Water & Wastewater



# Danfoss headquarter in Nordborg, Denmark



25.000 people, sales in >100 countries, production in 20  
Turnover 5,3 bn. €; Cooling, Power Solutions, Heating and  
**Danfoss Drives**



# Danfoss Drives has global presence



## Danfoss VSD centers

- USA (Rockford)
- Denmark (Graasten)
- Finland (Vaasa)
- China (Haiyan)
- India (Chennai)
- Germany (Flensburg)


## Danfoss Drives globally:

- ~ 4500 people
- Sales & service in > 80 countries
- 20 mill VSD supplied
- TS 16949

**First to introduce  
dedicated VSD  
for W&WW**




# The Water – Food – Energy - Nexus




As population grows, pressures mount

And the relationships between food, water, and energy supplies become critical

Because of growth in global population and the consumption patterns of an expanding middle class, in less than two decades three key demands will sharply increase ...



# A few statements from WEO 2016



## Chapter 9: Water - energy nexus:

- Water counts for **4 % of global electricity ~ Russia** (+ gasoline)
- Electricity consumption **expected to double** next 25 years
- The energy saving in “450 Scenario” is ~ **70 larger coal fired** power plants
- Leakage reduction to **6 %** as Denmark ~ 130 TWh saved ~ **Poland's** entire electricity need
- Water provision and wastewater treatment ~ **30 – 50 % of municipal electricity bills**
- The Aarhus Marselisborg WWTP facility in Denmark produces ~ **100 % more energy** than is consumed
- **VSD** mention multiple places as a key component for obtaining these benefits

# A case - Ontario Municipal Energy split




Figure 1.1. Ontario municipal energy use by facility type (eGWh), 2011

Municipal water and wastewater systems are typically the largest energy uses reported by Ontario municipal governments.



Table 1.1. Ontario Municipal Energy Use by Facility Type (2011)

| Municipal Energy Use                   | eGWh  | % of Overall |
|--|-------|--------------|
| Water & wastewater treatment & pumping | 2,235 | 38%          |
| Administrative offices                 | 765   | 13%          |
| Ice arenas                             | 599   | 10%          |
| Indoor recreation facilities           | 579   | 10%          |
| Libraries                              | 462   | 8%           |
| Community centres                      | 348   | 6%           |
| Police stations                        | 243   | 4%           |
| Fire stations                          | 193   | 3%           |
| Swimming pools                         | 155   | 3%           |
| Cultural facilities                    | 92    | 2%           |
| Ambulances                             | 64    | 1%           |


Note: Energy use reported in equivalent gigawatt-hours (eGWh), combining multiple energy sources.

Source: Ministry of Energy, O. Reg. 397/11, 2011 normalized data.



In Aarhus Denmark this wastewater treatment plant have net production of energy (234%) and still complying with the very strict outlet permissions.


# Why use VSD drives in the water and wastewater business? ..



## The benefits are typically:

- Better water quality
- Better asset protection
- Less maintenance cost
- Reduced energy cost
- Higher plant reliability/capacity


# The energy neutrality concept is a lot more than optimizing the wastewater facility




**Highly efficient components and VSDs in all process step is a precondition**




# High efficient components – means focus on Installed energy efficiency ...




Installed or "wire to air" efficiency is the trend (ASME PTC 13)




# Installed efficiency the important point ....



**Backchannel cooling vs tradition air-condition**



**AAF vs AFE harmonic mitigation solution**




**Basis for calculations:** LHD AC Drive, 0,1 €/kWh, 60 % load, 24/7 operation, 0,4 W AC/W removed

| Options             | Efficiency gained |
|---------------------|-------------------|
| IE 2 to IE 3 motor  | 0,9 %             |
| Backchannel cooling | ~ 2,5 %           |
| AAF vs AFE          | 1,6 – 3,0 %       |

} 2-4 %





| Options             | Savings % of Inv. of VSD |
|---------------------|--------------------------|
| Backchannel cooling | 12 – 20 %                |
| AAF vs AFE          | 7 – 23 %                 |
| <b>Total</b>        | <b>20 – 43 %</b>         |

# The energy neutrality concept is a lot more than optimizing the wastewater facility




**Highly efficient components and VFDs in all process step is a precondition**

# Well Field Model – VCS Odense DK > 40 % savings





# The energy neutrality concept is a lot more than optimizing the wastewater facility




**Highly efficient components and VFDs in all process step is a precondition**


# The pressure management/reduction concept



# Recent case from the US - Emerald Coast Utilities Authority



# The effect of pressure management, Gold Coast Water, Australia



Ref.: Guidelines for water loss reduction **giz**



On behalf of  
Federal Ministry  
for Economic Cooperation  
and Development



# Pressure management experience

## Experience from:

- 112 systems
- In 10 different countries

## Average result:

- 38 % reduction in pressure
- New breaks reduced by 53 %


## Other benefits:

- **Typical 38 % water leakage reduction**
- **Energy consumption reduced by 20 – 40 %**
- Extended asset lifetime
- Fewer network related complains

| Country                 | Water Utility or System | Number of Pressure Managed Sectors in study | Assessed initial maximum pressure (metres) | Average % reduction in maximum pressure | Average % reduction in new breaks | Mains (M) or Services (S) |
|-------------------------|-------------------------|---|--|---|-----------------------------------|---------------------------|
| Australia               | Brisbane                | 1   | 100  | 35%                                     | 28%                               | M,S                       |
|                         | Gold Coast              | 10  | 60-90                                      | 50%                                     | 60%                               | M                         |
|                         | Yarra Valley            | 4   | 100  | 30%                                     | 70%                               | S                         |
| Bahamas                 | New Providence          | 7   | 39   | 34%                                     | 28%                               | M                         |
| Bosnia Herzegovin       | Gracanica               | 3   | 50   | 20%                                     | 40%                               | M,S                       |
|                         |                         |   |  |   | 59%                               | M                         |
| Brazil                  | Caesb                   | 2   | 70   | 33%                                     | 72%                               | S                         |
|                         | Sabesp ROP              | 1   | 40   | 30%                                     | 58%                               | M                         |
|                         | Sabesp MO               | 1   | 58   | 65%                                     | 24%                               | S                         |
|                         | Sabesp MS               | 1   | 23   | 30%                                     | 38%                               | M                         |
|                         |                         |   |  |   | 80%                               | M                         |
|                         | SANASA                  | 1   | 50   | 70%                                     | 29%                               | S                         |
|                         |                         |   |  |   | 64%                               | M                         |
| Sanepar                 | 7                       | 45  | 30%  | 64%                                     | S                                 |                           |
|                         |                         |   |  | 50%                                     | M                                 |                           |
| Canada                  | Halifax                 | 1   | 56   | 18%                                     | 50%                               | M                         |
|                         |                         |   |  |   | 30%                               | M                         |
| Colombia                | Armenia                 | 25  | 100  | 33%                                     | 70%                               | S                         |
|                         | Palmira                 | 5   | 80   | 75%                                     | 50%                               | S                         |
|                         | Bogotá                  | 2   | 55   | 30%                                     | 94%                               | M,S                       |
| Cyprus                  | Lemesos                 | 7   | 52.5                                       | 32%                                     | 31%                               | S                         |
|                         |                         |   |  |   | 45%                               | M                         |
| England                 | Bristol Water           | 21  | 62   | 39%                                     | 40%                               | S                         |
|                         |                         |   |  |   | 25%                               | M                         |
|                         | United Utilities        | 10  | 47.6                                       | 32%                                     | 45%                               | S                         |
| Italy                   | Torino                  | 1   | 69   | 10%                                     | 72%                               | M                         |
|                         | Umbra                   | 1   | 130  | 39%                                     | 75%                               | S                         |
| USA                     | American Water          | 1   | 199  | 36%                                     | 45%                               | M,S                       |
| Total number of systems |                         | 112   |  |   |                                   |                           |
|                         |                         | Maximum                                     | 199  | 75%                                     | 94%                               | All data                  |
|                         |                         | Minimum                                     | 23   | 10%                                     | 23%                               | All data                  |
|                         |                         | Median                                      | 57   | 33.0%                                   | 50.0%                             | All data                  |
|                         |                         | Average                                     | 71   | 38.0%                                   | 52.5%                             | M&S together              |
|                         |                         | Average                                     |  | 36.5%                                   | 48.8%                             | Mains only                |
|                         |                         | Average                                     |  | 37.1%                                   | 49.5%                             | Services only             |


Ref:Thornton and Lambert 2007, Water Service Association of Australia Asset Management 2011 \*\* 16th January 2013, Coombe Abbey, Warwickshire

# The energy neutrality concept is a lot more than optimizing the wastewater facility



**Highly efficient components and VFDs in all process step is a precondition**

# The energy neutrality concept is a lot more than optimizing the wastewater facility



**Highly efficient components and VFDs in all process step is a precondition**

# Energy surplus producing wastewater facility

## Marselisborg WWTP Aarhus Denmark



**Size: 200.000 PE ~ 26.000 m<sup>3</sup>/d**

**No external carbon sources**

**142 % electricity in 2014**

**Excess heat ~2,1 GWh/year in 2014**

**Total energy produced ~ 192 %**

**Advanced real-time online sensor based process control**

**Mindset change:**

- Carbon harvesting
- Efficiency as goal


**Upgrade to highly efficient components based on ROI**

**SCADA fallback process control strategy**



**VSD's on all rotating equipment**

# Layout – Marselisborg wastewater facility



# The World Wide **first energy-neutral** catchment area – Marselisborg, Aarhus Water, Denmark

## Fact box

- Energy neutrality for the whole water cycle (*water supply + wastewater*)
- Catchment area for 200,000 people. No wind, solar or heatpump energy is produced
- Based on energy savings & household wastewater energy production (*no external carbon*)

| Marselisborg catchment area  | Status 2014     | Status 2016     |
|--|-----------------|-----------------|
| <b>Energy consumption</b>  |                 |                 |
| Water treatment, distribution [kWh] (avg. 0.51 kW/m <sup>3</sup> , high) | 3,1 mill        | 3,2 mill        |
| Wastewater transport [kWh]   | 0,7 mill        | 0,8 mill        |
| Marselisborg WWTP [kWh] (BOD <sub>5</sub> = 2,4/TN= 6,0/TP = 0.2)        | 3,4 mill        | 3,2 mill        |
| <b>Total energy consumption [kWh]</b>                                    | <b>7,2 mill</b> | <b>7,2 mill</b> |
| <b>Energy production</b>   |                 |                 |
| Electricity production [kWh]   | 4,4 mill        | 4,8 mill        |
| Heat production [kWh]  | 2,1 mill        | 2,6 mill        |
| <b>Total energy production [kWh]</b>                                     | <b>6,5 mill</b> | <b>7,4 mill</b> |
| <b>Own energy supply degree</b>  |                 |                 |
| Wastewater treatment process, electricity and heat [%]                   | 192 %           | 234 %           |
| Wastewater treatment process, electricity [%]                            | 142 %           | 150 %           |
| <b>Total Marselisborg catchment area [%]</b>                             | <b>94 %</b>     | <b>103 %</b>    |





**290 VFD's installed in catchment area**



# What has been done to achieve these results?


## Key elements for obtaining beyond Energy Neutrality:

- Process control based on online sensors (RAS, N & P, fall back strategy)
- VSD drives on all rotating equipment (from 40 % to 100 %)
- Carbon harvesting
- Highly efficient components (Bottom aeration, High Speed blowers ..)
- Deep process knowhow
- CHP installation (electricity & heat)



Bio-bus - showing where the fuel comes from  
Source: Wessex Water/Julian James Photography.

# Simultaneous Nitrification/Denitrification




  
**Oxygen uptake increase dramatic**




# Anammox on side-stream and partly nitrite shunt

## Side-stream Anammox



## Partly active Nitrite shunt

(Due to an out selection of the Nitrite Oxidizing Bacteria)



13

# Energy Neutrality and Reduced water loss in the water cycle

Advanced real time process control/modelling

Real time sensors (level, flow, analytical, pressure etc.)


Energy neutrality & Reduced Water loss

Real time controllability mainly via VFD's

High efficient components

**Also referred to as:**  
**Industry 4.0, Water 4.0, Digitalization of the water industry**

# How does the concept fit the big agendas.....



Energy savings – **the energy reduction agenda**

Water savings – **the water scarcity agenda**

GHG savings – **the CO<sub>2</sub> agenda**


Longer assets life time  
Higher facility capacity } **the asset inv. agenda**

OPEX savings  
Good ROI  
Less maintenance } **the water cost agenda**

Less customer complaints

More stable processes/higher controllability

# Turning the Water Industry into Energy Neutrality + low water leakage





**ENGINEERING  
TOMORROW**

<http://www.danfoss.com/energy-and-water/#/>  
<http://drives.danfoss.com/industries/water-and-wastewater/#/>