

# Project Shotover

What did we learn? What did we achieve?




- ❖ John Crawford, Principal – Wastewater Engineering, Beca
- ❖ Simon Mason, Contract Manager – 3 Waters, QLDC

# Why an Upgrade ?

- Grossly overloaded oxidation pond system
- Pristine receiving environment
- New consents ramp up WWTP performance expectations
- Rapid and major growth in & around Queenstown



# Growth




- 34:1 International visitor to local ratio (annual basis)
- Major residential and commercial development underway and more planned
- Officially 2.6%. Actually more like 4.5% pa compounding



# Procurement Model

- Client appointed advisory team throughout project
- Design, build, operate model (FIDIC Gold Book)
- Three short listed parties
- Prolonged evaluation/negotiation process

# Timeline






# Project/Plant Staging

- Staging based on consent TN threshold and projected growth rate
- Left Proposers to determine final staging configuration:
  - meet the consent conditions
  - minimum requirements for loading to 2026, and
  - most efficient use of existing infrastructure

# Project/Plant Staging



# The Upgrade

- Two process streams
  - 2/3 to new activated sludge plant
  - 1/3 through pond system
- Blended effluent stream to UV disinfection







# MLE Process

- Overall reactor dimensions – 83 x 26 x 6m
  - Three Pre-Anoxic Zones (180 m<sup>3</sup> each)
  - Anoxic Zone (2,675 m<sup>3</sup>)
  - Swing Zone (1,490 m<sup>3</sup>)
  - Aeration Zone (4,760 m<sup>3</sup>)
- 34m suction dredge clarifier



# Other inclusions

- Grit removal & flow splitter
- Blower building (4 x 55kW blowers)
- Sludge dewatering (2 x centrifuges)
- Recycled water treatment & distribution
- Pond discharge pump station
- Odour treatment
- Septage reception facility



# Design Process – Observations and Challenges


- Geotechnical design
- Peer reviews and client reviews
- Design workshops
- Vendor input

# Commissioning and Performance

	Consent Limits		Clarifier Effluent		Blended Discharge Effluent	
	Annual Mean	Upper 95 <sup>th</sup> %ile	Annual Mean	Upper 95 <sup>th</sup> %ile	Annual Mean	Upper 95 <sup>th</sup> %ile
<b>BOD<sub>5</sub> (g/m<sup>3</sup>)</b>	30	50	-	-	6.0	11.8
<b>TSS (g/m<sup>3</sup>)</b>	30	50	4.1	8.0	8.5	17
<b>NH<sub>3</sub>-N (g/m<sup>3</sup>)</b>	15	25	0.1	0.3	10.1	16.4
<b>TN (g/m<sup>3</sup>)</b>	20	35	5.5	7.6	19.4	28
<b>TP (g/m<sup>3</sup>)</b>	7.5	10	-	-	4.4	6.9
<b>E.coli (cfu/100ml)</b>	260 geomean	260 geomean	-	-	19.9	80.0


# What Actually Happened?

Project Shotover - Projected Flows and Capacity




The GFC dissipated and the Wakatipu Basin became even more popular

# Flow Variance – Wet Weather



- 1.7xADF During most significant event in 19 mths
- Typical rainfall events, approx. 30% increase in flow

# Flow Variance – Seasonal



- Seasonal peak 1.2 x ADF
- Seasonal trough 0.83 x ADF
- i.e Very stable, low seasonal amplitude
- Red illustrates year on year growth



# Lessons Learned

- Learnings from Project Pure
- Risk allocation
- Design Build – Pros & Cons



# Conclusions

- Project Shotover has delivered well on QLDC's requirements
- D&B not a silver bullet

An aerial photograph of a wastewater treatment plant at dusk. The plant features several large circular tanks, rectangular aeration basins with metal walkways, and a central control building. The facility is illuminated by warm lights, contrasting with the cool tones of the twilight sky. In the background, a large mountain range is silhouetted against the fading light. A road with light trails from passing vehicles is visible in the foreground.

QUESTIONS?